



HUBLI REGIONAL TESTING CENTER LLP

Building Materials | Steel | Soil | NDT

F-5 & B1, Jolad Enclave, Opp: Railway Officers

Guest House, Keshwapur, Hubli - 580 020

: regionaltestingcenterhubli@gmail.com : 9900989338 | 7019200651



TC-16126

An ISO/IEC 17025:2017 Certified

TEST REPORT

ULR No: TC161262500000038F	TR No: HRTC/TR/25-26/55	TR Date: 22-08-2025
Internal Job Order No and Date	Date of receipt	Date of testing
HRTC/JO/25-26/55, 20-08-2025	20-08-2025	21-08-2025
Name and Address of the customer*	Gajanan Trading Company.Pvt.Ltd	
Project / Site details*	Narsinga Reality, Airlink Luxur Apartment, Gokul Road, Hubli	
Customer inward Ref*	Letter Dated: 20-08-2025	
Sample description and quantity received*	KOTI TMT Fe 550D Steel Bars -8mm, 10mm, 12mm, 16mm, 20mm, 25mm-Each Dia of the bar 1 set	
Grade of Steel*	Fe 550D	
Location of test	In Lab	
Tested By / on	S.D.Kokane , 21-08-2025	

TMT Bars Test Details						
Sl No	Nominal Dia (mm)	Mass (Kg/m)	Elongation (%)	Yield Stresss (N/mm2)	Ultimate Tensile Strength (N/mm2)	Test Method
1	8	0.398	15.22	704.339	782.446	IS 1608(Part-1)-2022/ IS 1786-2008 (RA-2018)
2	8	0.394	17.31	621.837	690.576	
3	10	0.618	15.38	647.402	718.913	
4	10	0.612	14.93	642.252	713.443	
5	10	0.618	15.38	647.402	718.913	
6	12	0.900	17.83	671.696	743.742	
7	12	0.900	15.15	671.696	743.742	
8	12	0.882	16.94	676.931	752.136	
9	16	1.578	21.93	611.332	679.087	
10	16	1.583	20.36	610.472	725.605	
11	16	1.600	19.77	604.062	717.986	
12	20	2.480	21.75	654.311	743.986	
13	20	2.520	21.23	643.916	732.166	
14	20	2.500	21.36	649.072	738.029	
15	25	3.860	16.16	649.089	729.785	
16	25	3.900	17.58	642.439	722.308	
17	25	3.880	17.55	645.740	726.020	



Location: Office

Retention: 2 Years
Page 1 of 2

F.No: HRTC/F/CUS/04 Rev 1



Scanned with OKEN Scanner



HUBLI REGIONAL TESTING CENTER LLP

Building Materials | Steel | Soil | NDT

F-5 & B1, Jolad Enclave, Opp: Railway Officers

Guest House, Keshwapur, Hubli - 580 020


: regionaltestingcenterhubli@gmail.com : 9900989338 | 7019200651




TC-16126

An ISO/IEC 17025:2017 Certified

- Note:** 1. This report is confidential between HRTC and customer
2. This report shall not be copied or duplicated and relates only to the item tested
3. * Details as furnished by Client


Tested By
S.D.Kokane




Authorized By
Mahesh Marampudi
Quality Manager

End of report

